



The ample space around the core of the in-line helical axial turbine allows foreign matter to pass through the meter without clogging.



Applications

For main supply lines, agriculture and industry

Available Sizes

2" (50mm)

Features

- Minimum head loss
- High accuracy
- Hermetically sealed register with glass lens
- Optional electrical output: EV (volume), EF (rate of flow) or DIALOG
- Not sensitive to dirt



 \mathbf{WMR} type dial


Technical Specifications


| Maximum Working Pressure | 16 bar | | | | |
|----------------------------|------------------------|--|--|--|--|
| Maximum Liquid Temperature | 55°C | | | | |
| Body | Iron, polyester coated | | | | |
| Connection | 2" BSP coupling | | | | |



Dimensions

| Model | WMR | | |
|-----------------------------------|--------|-----|--|
| Nominal size | (mm) | | |
| Nominal size | (inch) | 2 | |
| L - Length without couplings (mm) | | 200 | |
| H - Height (mm) | | 98 | |
| h - Height (mm) | | 40 | |
| Weight (kg) | | 2.3 | |
| Weight with couplings (kg) | | 3.7 | |






Performance data:

| | odel MR | QMAX Maximum | Qn ISO 4064 | Qn Nominal | Qt Transitional | Qmin Minimum | Starting Flow | Maximum register | Smallest readable | Accuracy between | Accuracy between |
|-------|------------|------------------------|-----------------------|----------------------|---------------------------|------------------------|------------------|-------------------------|----------------------|---------------------|---------------------|
| Nomir | nal size | flowrate (m3/h) | (m3/h) | Flowrate (m3/h) | Flowrate (m3/h) | Flowrate (m3/h) | (m3/h) | capacity (m3) | unit (liter) | Qmax & Qt | Qt & Qmin |
| (mm) | (inch) | | | | , , | | | , , | , , | | |
| 50 | 2 | 40 | 15 | 20 | 2 | 0.45 | 0.15 | 10 ⁶ | 1 | ±2% | ±5% |

Head Loss Curve



Installation Requirements

- · The water meter may be installed in any position. For non-horizontal position the flow shall be upwards.
- The meter shall be full of water while operating.
- Prior to installation of a meter the pipeline shall be thoroughly flushed.
- Straight pipe section of the same diameter D as the meter, having lengths of 10D and 5D shall be installed
- upstream and downstream of the meter respectively.



